



Test raport - akumulator żelowy VIPOW 6V 4.5Ah

№:2014071404

Item No	6V4.5AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	6.45~6.6	6.53~6.57			Pass
3	Dimension (±2mm)	L: 70 W: 48 H: 100 Th: 106	70*48*100*106			Pass
4	20 hours rate	0.225 A discharge T≥19.5h	20h 49m 24s			Pass
5	27min	4.5 A discharge T≥30m	36m 59s	37m 43s		Pass
6	3C	13.5 A discharge T≥7m	08m 41s	08m 53s		Pass
7	Weight(kg)		0.69	0.70	0.69	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109