



Test report - akumulator żelowy VIPOW 6V 12Ah

№:2014071406

Item No	6V12AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	6.45~6.6	6.49~6.53			Pass
3	Dimension (±2mm)	L: 151 W: 51 H: 94 Th: 100	151*51*94*100			Pass
4	20 hours rate	12 A discharge T≥19.5h	20h 28m 24s			Pass
5	27min	12 A discharge T≥30m	35m 41s	36m 34s		Pass
6	1C	36 A discharge T≥7m	08m 45s	08m 02s		Pass
7	Weight(kg)		1.76	1.75	1.78	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109