



Akumulator żelowy VIPOW 12V 17.0Ah

№:2014070903

Item No	12V17AH	Production Date	2014-7-9	Test Q'TY	100	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result		Judge	
1	Appearance	No deform, clear mark	Well appearance		Pass	
2	Terminal Volts	12.90~13.20	13.04~13.11		Pass	
3	sdsdDimension (±2mm)	L: 181 W: 77 W: 167 TH: 167	181*77*167*167		Pass	
4	20hours rate	0.9A discharge T≥19.5H	20H07"18		Pass	
5	27min	18A discharge T≥27min	34"43	33"51	Pass	
6	3C	54A discharge T≥7min	7"49	7"45	Pass	
7	Weight(kg)		4.82	4.85	4.83	Pass
Conclusion		Pass	Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109