



Test report - akumulator żelowy VIPOW 12V 7.5Ah

№:2014071311

Item No	12V7.5AH	Production Date	2014-7-13	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	12.90~13.20	13.05~13.12			Pass
3	Dimension (±2mm)	L: 151 W: 65 H: 94 Th: 100	151*65*94*100			Pass
4	20 hours rate	0.375 A discharge T≥19.5h	21h 32m 16s			Pass
5	27min	7.5 A discharge T≥27min	39m 45s	38m 27s		Pass
6	3C	22.5A discharge T≥7min	8m 39s	8m 45s		Pass
7	Weight(kg)		2.16	2.17	2.17	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109