



## Test raport - akumulator żelowy VIPOW 12V 10Ah

№:2014071212

Item No	12V10AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A <sub>c</sub> =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	12.90~13.20	13.03~13.16			Pass
3	Dimension (±2mm)	L: 151 W: 65 H: 111 Th: 117	151*65*111*117			Pass
4	20 hours rate	0.5 A discharge T≥19.5h	20h 23m 48s			Pass
5	27min	10 A discharge T≥27min	32m 24s	34m 26s		Pass
6	3C	30 A discharge T≥7min	8m 36s	8m 54s		Pass
7	Weight(kg)		2.99	2.97	2.99	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109