



Test raport - akumulator żelowy VIPOW 12V 12Ah

№:2014071211

Item No	12V12AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	12.90~13.20	13.06~13.14			Pass
3	Dimension (±2mm)	L: 151 W: 98 H: 96 Th: 100	151*98*96*100			Pass
4	20 hours rate	0.6 A discharge T≥19.5h	22h 14m 41s			Pass
5	27min	12 A discharge T≥27min	38m 21s	39m 51s		Pass
6	3C	36 A discharge T≥7min	8m 55s	8m 43s		Pass
7	Weight(kg)		3.47	3.49	3.47	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109