



Test raport - akumulator żelowy VIPOW 12V 14Ah

№:2014071210

Item No	12V14AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	12.90~13.20	13.06~13.14			Pass
3	Dimension (±2mm)	L: 151 W: 98 H: 96 Th: 100	151*98*96*100			Pass
4	20 hours rate	0.7 A discharge T≥19.5h	20h 1m 41s		Pass	
5	27min	14 A discharge T≥27min	31m 21s	30m 51s	Pass	
6	3C	42A discharge T≥7min	7m 55s	7m 43s	Pass	
7	Weight(kg)		3.58	3.60	3.58	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109