



Test raport - akumulator żelowy VIPOW 12V 20Ah

Nº:2014070904

Item No	12V 20AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	12.90~13.20	13.06~13.14			Pass
3	Dimension (±2mm)	L: 181 W: 77 H: 167 Th: 167	181*77*167*167			Pass
4	20hours rate	1 A discharge T≥19.5h	19h 34m 56s		Pass	
5	27min	20 A discharge T≥27min	34m 59s	35m 43s	Pass	
6	3C	60 A discharge T≥7min	7m 49s	7m 45s	Pass	
7	Weight(kg)		5.18	5.15	5.15	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109