



Test raport - akumulator żelowy VIPOW 12V 3.3Ah

№:2014071314

Item No	12V3.3AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	12.90~13.20	13.10~13.15			Pass
3	Dimension (±2mm)	L: 134 W: 67 H: 61 Th: 67	134*67*61*67			Pass
4	20 hours rate	0.165 A discharge T≥19.5h	19h 45m 03s			Pass
5	27min	3,3 A discharge T≥27min	30m 57s	29m 21s		Pass
6	3C	9.9 A discharge T≥7min	7m 16s	7m 24s		Pass
7	Weight(kg)		1.36	1.36	1.36	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109