



Test raport - akumulator żelowy VIPOW 12V 40.0Ah

№:2014070909

Item No	12V40AH	Production Date	2014-7-14	Test Q'TY	5
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing
	Test Item	Requirement of test	Test result		Judge
1	Appearance	No deform, clear mark	Well appearance		Pass
2	Terminal Volts	12.90~13.20	13.08~13.13		Pass
3	sdsdDimension (±2mm)	L: 196 W: 166 H: 176 Th: 176	196*166*176*176		Pass
4	20hours rate	2A discharge T≥19.5h	20h 40m 34s		Pass
5	27min	40A discharge T≥27m	33m 21s	33m 53s	Pass
6	3C	120A discharge T≥7m	8m 12s	8m 23s	Pass
7	Weight(kg)		12,91	12.88	12.85
Conclusion	Pass		Review	Lizhangzuo	Approved
					Linianshu

HW/QM-Q-C109