



Test raport - akumulator żelowy VIPOW 12V 55.0Ah

№:2014070910

Item No	12V55AH	Production Date	2014-7-14	Test Q'TY	5
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing
	Test Item	Requirement of test	Test result		Judge
1	Appearance	No deform, clear mark	Well appearance		Pass
2	Terminal Volts	12.90~13.20	13.09~13.15		Pass
3	sdsdDimension (±2mm)	L: 229 W: 138 H: 222 Th: 222	229*138*222*222		Pass
4	20hours rate	2A discharge T≥19.5h	20h 46m 12s		Pass
5	27min	55A discharge T≥27m	36m 34s	35m 27s	Pass
6	3C	165A discharge T≥7m	8m 24s	8m 45s	Pass
7	Weight(kg)		16,90	16.92	16.94
Conclusion	Pass		Review	Lizhangzuo	Approved
					Linianshu

HW/QM-Q-C109