



Test raport - akumulator żelowy VIPOW 12V 75.0Ah

№:2014070911

Item No	12V75AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	12.90~13.20	13.04~13.10			Pass
3	sdsdDimension (±2mm)	L: 260 W: 169 H: 222 Th: 222	260*169*222*222			Pass
4	10hours rate	7.5A discharge T≥9.5h	9h 41m 16s		Pass	
5	27min	75A discharge T≥27m	37"45	36"52	Pass	
6	3C	225A discharge T≥7m	8"59	8"43	Pass	
7	Weight(kg)		23.22	23.24	23.14	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109