



Test report - akumulator żelowy VIPOW 12V 100Ah

№:2014071306

Item No	12V100AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result		Judge	
1	Appearance	No deform, clear mark	Well appearance		Pass	
2	Terminal Volts	12.90~13.20	13.03~13.10		Pass	
3	Dimension (±2mm)	L: 333 W: 172 H: 218 Th: 221	333*172*218*221		Pass	
4	10hours rate	10.2A discharge T≥9.5H	9H42M27S		Pass	
5	27min	102A discharge T≥27min	35m18S		Pass	
6	1C	60A discharge T≥1h	1H1M27S		Pass	
7	Weight(kg)		31.02	31.14	Pass	
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109