



Test report - akumulator żelowy VIPOW 12V 250Ah

№:2014071308

Item No	12V250AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result		Judge	
1	Appearance	No deform, clear mark	Well appearance		Pass	
2	Terminal Volts	12.90~13.20	13.04~13.11		Pass	
3	Dimension (±2mm)	L: 520 W: 261 H: 220 Th: 220	520*261*220*220		Pass	
4	10hours rate	25A discharge T≥9.5h	10h 01m 28s		Pass	
5	27min	250A discharge T≥27min	32m 19s		Pass	
6	1C	150A discharge T≥1h	1h 1m 27s		Pass	
7	Weight(kg)		72.64	72.56	Pass	
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109