



## Test raport - akumulator żelowy VIPOW 6V 3.3Ah

№:2014071403

Item No	6V3.3AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A <sub>c</sub> =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	6.45~6.6	6.53~6.57			Pass
3	Dimension (±2mm)	L: 125 W: 33 H: 60 Th: 66	125*33*60*66			Pass
4	20 hours rate	0.16 A discharge T≥19.5h	19h 45m 36s			Pass
5	27min	3.2 A discharge T≥30min	32m 45s	32m 18s		Pass
6	3C	9.6 A discharge T≥7m	07m 12s	07m 16s		Pass
7	Weight(kg)		0.66	0.66	0.67	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109