



Test report - akumulator żelowy VIPOW 6V 100Ah

№:2014071410

Item No	6V100AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result		Judge	
1	Appearance	No deform, clear mark	Well appearance		Pass	
2	Terminal Volts	6.45~6.6	6.45~6.54		Pass	
3	Dimension (±2mm)	L: 195 W: 171 H: 207 Th: 212	195*171*207*212		Pass	
4	10 hours rate	10 A discharge T≥10h	9h 34m 27s		Pass	
5	27min	100 A discharge T≥27min	31m 18s		Pass	
6	1C	60 A discharge T≥1h	1h 02m 27s		Pass	
7	Weight(kg)		15.08	15.04	Pass	
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109