



Test report - akumulator żelowy VIPOW 12V 33Ah

№:2014071315

Item No	12V33AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	12.90~13.20	13.09~13.16			Pass
3	Dimension (±2mm)	L: 194 W: 132 H: 172 Th: 172	194*132*172*172			Pass
4	20hours rate	1.65A discharge T≥19.5h	21h 13m 56s		Pass	
5	27min	33A discharge T≥27min	35m 54s	36m 36s	Pass	
6	1C	99A discharge T≥1h	8m 12s	8m 19s	Pass	
7	Weight(kg)		9.86	9.88	9.80	Pass
Conclusion		Pass	Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109