



## Test report - akumulator żelowy VIPOW 12V 9Ah

№:2014071316

Item No	12V9AH	Production Date	2014-7-14	Test Q'TY	10	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A <sub>c</sub> =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result		Judge	
1	Appearance	No deform, clear mark	Well appearance		Pass	
2	Terminal Volts	12.90~13.20	13.12~13.16		Pass	
3	Dimension (±2mm)	L: 151 W: 65 H: 94 Th: 100	151*65*94*100		Pass	
4	20 hours rate	0.4 A discharge T≥19.5h	19h 41m 47s		Pass	
5	27min	9 A discharge T≥27min	36m 54s	35m 31s	Pass	
6	3C	27 A discharge T≥7min	8m 12s	8m 17s	Pass	
7	Weight(kg)		2.40	2.40	2.42	
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109