



Test raport - akumulator żelowy VIPOW 12V 26Ah

№:2014070913

Item No	12V 26AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result		Judge	
1	Appearance	No deform, clear mark	Well appearance		Pass	
2	Terminal Volts	12.90~13.20	13.04~13.13		Pass	
3	Dimension (±2mm)	L: 175 W: 165 H: 125 Th: 125	175*165*125*125		Pass	
4	20hours rate	1.3A discharge T≥19.5h	20h 16m 14s		Pass	
5	27min	26A discharge T≥27min	31m 47s	32m 25s	Pass	
6	3C	78A discharge T≥7min	7m 21s	7m 23s	Pass	
7	Weight(kg)		8.03	8.06	8.02	
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109