



Test raport - akumulator żelowy VIPOW 4V 4.9Ah

№:2014071410

Item No	4V4.9AH	Production Date	2014-7-14	Test Q'TY	5	
Test standard: GB2828-87 Normal test level II AQL Value: 2.5			A _c =0 Re =1	Inspector	Lijing	
	Test Item	Requirement of test	Test result			Judge
1	Appearance	No deform, clear mark	Well appearance			Pass
2	Terminal Volts	4.3~4.4	4.33~4.38			Pass
3	Dimension (±2mm)	L: 48 W: 48 H: 102 Th: 106	48*48*102*106			Pass
4	20 hours rate	0.245 A discharge T≥19.5h	20h 03m 18s			Pass
5	27min	4.9 A discharge T≥30min	29m 45s	30m 18s		Pass
6	3C	14.7 A discharge T≥7m	07m 53s	07m 46s		Pass
7	Weight(kg)		0.54	0.55	0.55	Pass
Conclusion	Pass		Review	Lizhangzuo	Approved	Linianshu

HW/QM-Q-C109